

17 April 2019

Ref: 31653/JV/QL

Contact: John Vanderzon
Phone: +61 8 8274 2188
E-mail: jvanderzon@aga.asn.au



Mr Steve Bensted
Rinnai Australia Pty Ltd
61 Malcolm Road
Braeside, VIC, 3195

Dear Mr Steve Bensted,

**Re: Rinnai Australia Pty Ltd (Brivis Climate Systems)
Ducted Gas Central Heaters
Brivis StarPro SP5 Series: AGA Application 17026, AGA Certificate 8040**

I refer to your Application for Modification received on 19 July 2018 and our further correspondence. This Application is for changes to product already certified under coverage of AGA certifications **8040** and the modifications/variations concern:

- certification update to the current standard.
- specification update following our last PVA (2018), to correct minor observations recorded.

In support of your applications I acknowledge receipt of:

- Revised specification documents, received 16 April 2019.

Following my desktop review I confirm no re-assessment is required for the certification update. The updated documentation submitted also satisfies corrections for minor observations of information noted at the PVA.

All work for this project is now complete and I am pleased to enclose the following:

- Revised AGA Certificate 8040.
- Revised Appliance Specification 04.
- Details of the certification entry as it will appear in the "Directory of AGA Certified Products", as found on our website www.aga.asn.au.

Please review the enclosed documentation and advise if any details are incorrect or inadequate.

Yours sincerely

A handwritten signature in black ink that reads 'John Vanderzon'.

John Vanderzon
Client Manager, AGA



AGA CERTIFIED PRODUCT

JAS-ANZ



www.jas-anz.org/register

Certificate Holder: **RINNAI AUSTRALIA PTY LTD**

ABN/ACN No. (if applicable): **64 096 079 088**

Manufacturer: **RINNAI AUSTRALIA PTY LTD
(BRIVIS CLIMATE SYSTEMS)**

Agent (if applicable): **N/A**

Type of Appliance: **DUCTED GAS CENTRAL HEATERS**

Model No. & Description: **RINNAI BRIVIS
BRIVIS STARPRO SP5 SERIES:
SP521IN, SP521IN-XA, SP530IN, SP530IN-XA,
SP535IN, SP521EN, SP521EN-XA, SP530EN,
SP530EN-XA, SP521UN, SP521UN-XA, SP530UN,
SP530UN-XA, SP535UN**
SP5 = StarPro 5 star, I = Internal, E = External,
U = Universal, N = Natural gas, XA = extra air

(Refer www.aga.asn.au for more details)


Relevant Standard(s): **AS/NZS 5263.1.6 – 2016
AS 5263.0 – 2013**

Gas Type(s): **NATURAL GAS**

This is to certify that the particular **APPLIANCE** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) The Certificate Holder undertakes to apply the AGAMark under licence or affix the AGA's Certification Badge (an image of which is endorsed hereon) to every appliance of the above-named model(s) throughout the currency of the certification;
- (iii) This Certificate remains the property of the AGA; and
- (iv) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate and Certification Badges to the AGA upon request.



John Vanderzon

Client Manager

Certificate Authorised

Certificate first issued: **17 December 2013**

Certificate No: **8040**

This copy valid from: **17 April 2019**

Refer specification issue: **04**

QF711/12

Directory Certificate Entry

Domestic and Commercial Appliances

Indirect Fired Air Heaters

Ducted Air Heaters

Rinnai Australia Pty Ltd

(61 Malcolm Rd., Braeside, 3195 VIC AUSTRALIA Ph: 03 9271 6501)

Relevant Standard/s: *AS/NZS 5263.1.6 | 2016 | Gas appliances - Part 1.6: Indirect gas-fired ducted air heaters | 6/10/2016*
AS 5263.0 | 2013 | Gas appliances, Part 0: General requirements | 17/09/2013

8040	12.13	<i>Rinnai Bravis StarPro SP5 Series</i>	<i>Annual</i>	<i>Star</i>	<i>TGC</i>	<i>Type of Gas</i>		
			<i>Energy Cons.</i>	<i>Rating/</i>		<i>Nat</i>	<i>TLP</i>	<i>Town</i>
			<i>(MJ/year)</i>	<i>Shading</i>				
		SP521IN, SP521IN-XA, SP521UN, SP521UN-XA, SP521EN, SP521EN-XA	133	5.0/150°	90			N
		SP530IN, SP530IN-XA, SP530UN, SP530UN-XA, SP530EN, SP530EN-XA	133	5.0/150°	130			N
		SP535IN, SP535UN	133	5.0/150°	146			N

Note: - SP5 = StarPro 5 star, I = Internal, E = External, U = Universal, N = Natural gas & XA = Extra Air

Wednesday, 17 April 2019